

ENVIRONMENTAL

TESTING, Inc.

100 South Cass Street
P.O. Box 138
Middletown, DE 19709-0138
302-378-5341
302-378-9882 (FAX)

March 24, 2016

Lance Fisher
Fisher's Environmental, LLC
809 Maryland Avenue
DelMar, MD 21875

Dear Lance:

A final visual inspection and air sampling following abatement of asbestos containing material by Fisher's Environmental, LLC, DelMar, Maryland, was conducted at Wight Bay Condominiums, Unit (b) [REDACTED], at 4709 Coastal Highway, Ocean City, Maryland by Environmental Testing, Inc. (ETI; Keith Staton) on March 23, 2016. **Results of visual inspection and final clearance air sampling indicate that all designated drywall/joint compound was properly removed and that the air sample results met clearance criteria required by Maryland Department of the Environment (MDE).**

If you have any questions concerning this information, please don't hesitate to contact me.

Cordially,

Gary Hayes

Gary Hayes
Environmental Consultant

ETI Project #16-080